

**From: Industrial Waste and Pollution Prevention Section**

Direct Dial: (651) 602-4727 Fax Number: (651) 602-4730

E-Mail: [karalynn.marr@metc.state.mn.us](mailto:karalynn.marr@metc.state.mn.us)

June 10, 2016

**To: Michael Austin, Associate Director, Safety & Environmental Protection**

U of M - St. Paul Heating Plant

501 SE 23rd Ave

Minneapolis, MN 55455

**RE: INDUSTRIAL DISCHARGE PERMIT NUMBER 1057**

**FOR THE FACILITY LOCATED AT**

1952 Commonwealth Ave

Falcon Heights, MN 55108

TRANSMITTED HERewith is the reissued Industrial Discharge Permit for the above referenced facility. This Permit has been reissued by Metropolitan Council Environmental Services for the period specified, and it supersedes the previous Permit. The discharge of Industrial Waste into the Metropolitan Disposal System is hereby allowed, subject to any and all provisions of the Waste Discharge Rules for the Metropolitan Disposal System, and this Permit.

THE INDUSTRIAL DISCHARGE PERMIT contains Discharge Limitations, Self-Monitoring and Reporting Requirements, General Permit Conditions, Specific Permit Conditions, and a Compliance Schedule (if necessary). Any failure to submit the required Self-Monitoring Reports (SMRs), or any reports required by a Compliance Schedule, is a violation of this Permit. The Permit Number shall be included on all correspondence regarding this Permit.

THE PERMITTEE is reminded that reissuance of this Permit is not automatic; the Permittee must apply for reissuance at least 60 days prior to the Permit expiration date. If questions arise, contact Karalynn Marr at (651) 602-4727 or via email at [karalynn.marr@metc.state.mn.us](mailto:karalynn.marr@metc.state.mn.us).

Sincerely,



Robert Nordquist, P.E.

Industrial Waste Manager

MCES Industrial Waste & Pollution Prevention Section



**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

**INDUSTRIAL DISCHARGE PERMIT**

Pursuant to the provisions of Minnesota Statutes Chapter 473 as amended and the Waste Discharge Rules for the Metropolitan Disposal System (MDS) permission is hereby granted to

U of M - St. Paul Heating Plant

1952 Commonwealth Ave

Falcon Heights, MN 55108

for the discharge of Industrial Waste into public sewers within the community of Falcon Heights tributary to the Metropolitan Council's Metropolitan Wastewater Treatment Plant.

This Permit is granted in accordance with the application previously submitted and in consideration of the plans, specifications and data contained in the application.

Discharge Limitations, Self-Monitoring and Reporting Requirements, Compliance Schedules, General Permit Conditions, and Specific Permit Conditions are contained in following sections of this Permit.

EFFECTIVE DATE: June 01, 2016

EXPIRATION DATE: May 31, 2019

Issued by METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES



June 6, 2016

---

General Manager, or duly authorized representative  
Larry Rogacki, Assistant General Manager  
Support Services Business Unit

---

Date

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

A. Discharge Limitations

1. Discharge Limits at Sample Location(s):

The following Discharge Limits are based on the listed Rule(s) for the specified sampling location(s):

**SP-04: Flow-proportionally combined composite of SP-01, SP-02, and SP-03.**

Applicable Rule	Rule Description	Regulated Pollutant	Standard (mg/L)
Waste Discharge Rule 401.00	MCES Local Pretreatment Standards	Cadmium	1.0
		Chromium	6.2
		Copper	4.1
		Cyanide, total	4.1
		Lead	1.0
		Mercury	0.002
		Nickel	6.2
		Zinc	6.2
		pH Minimum (Standard Units)	5.0
		pH Maximum (Standard Units)	11.0

Local pretreatment standards for metals and cyanide are the maximum for any 24 hour period.

pH standards are continuous and apply at all times.

MCES Local Pretreatment Standards are listed in Attachment B.

2. Prohibited Waste Discharges

Prohibited wastes are specific in Waste Discharge Rule 406 and include, but are not limited to the following: (a) Flammable, explosive and corrosive wastes, gasoline, fuel oil, lubricating oil, hydraulic oil, motor oil, or grease; (b) Wastes that are likely to obstruct the flow within public sewers: grease, fat or oil of animal or vegetable origin, solid wastes, garbage, guts, bones, ash, sand, rags, lime, metal, wood, plastic, glass, or yard wastes; (c) Wastes that are likely to cause interference, pass-through, or operational problems: slug discharges, toxic chemicals, poisons, dyes, or inks; (d) Wastes that are likely to cause a public nuisance: noxious, malodorous, or foam producing substances; (e) Hazardous wastes, as defined by Minnesota Statutes; and (f) Waste generated outside of the Metropolitan Area.

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

B. Self-Monitoring and Reporting Requirements

1. Following are the specific monitoring point location(s), sample collection frequency, volume determination, sample compositing, and (if necessary) the calculation methods required by this Industrial Discharge Permit. Representative wastewater samples shall be collected at each sampling point (SP) by the Permittee in accordance with these requirements and Waste Discharge Rules 212, 213, and 215. **These samples shall be collected on normal operating days based on the corresponding frequency listed in Attachment A.**

i) Monitoring Point:

**SP-01: Process Wastewater Sump**

Samples shall be collected at the process waste sump inside the building.

**SP-02: Southwest Maintenance Hole**

Samples shall be collected from the southeast drop pipe inside the southwest maintenance hole. Only the discharge from boiler 8 flows through this point.

**SP-03: Southeast Maintenance Hole**

Samples shall be collected from the north drop pipe inside the southeast maintenance hole. Only the discharge from boiler 7 flows through this point.

**SP-04: Flow-proportionally combined composite of SP-01, SP-02, and SP-03.**

The samples collected from SP-01, SP-02 and SP-03 shall be combined flow-proportionally into one total process sample.

ii) Collection Frequency:

A minimum of four grab samples shall be taken at each of the monitoring points (SP-01, SP-02 and SP-03) on a normal operating day.

iii) Typical Operating Days:

Each calendar day with typical or greater than typical discharge activities, as allowed under this Permit, shall be considered one operating day. All other days shall be calculated as an appropriate fraction of one operating day.

iv) Volume Determination:

The reporting period and sampling day total facility discharge volumes shall be determined by readings of the three incoming water meters less the calculated evaporative loss. Industrial waste volumes shall be calculated by subtracting the domestic estimate of 20 gallons/employee/day from the calculated total facility discharge volume.

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

B. Self-Monitoring and Reporting Requirements (continued)

v) Compositing Method:

The grab samples from each of the monitoring points shall be composited together on an equal volume basis. The resulting composites shall be combined into a total process sample for SP-04 based on the ratio of discharge through each point during the reporting period or sampling day.

Results from the analysis of the daily composite sample shall be compared to Discharge Limits listed in Section A.1. for compliance determinations.

vi) MCES Strength Charge:

The MCES Strength Charge is based on total facility concentrations for Chemical Oxygen Demand (COD) and Total Suspended Solids (TSS), and the total facility discharge volume for each reporting period. MCES Strength Charges are determined in accordance with Waste Discharge Rule 302.

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

B. Self-Monitoring and Reporting Requirements (continued)

2. Parameters

Chemical analysis, in accordance with Waste Discharge Rule 216, of the sample(s) representing the waste discharged through the specific monitoring point(s), shall be performed for the following parameters:

**See Attachment A**

3. Reporting Requirements

The following Self-Monitoring Reports (SMRs) shall be submitted as hard-copy or electronically using the MCES Industrial Online Reporting System at the specified frequency:

a. Reporting Period Summary SMR

The Permittee shall submit a complete report 2 times per year, according to the following schedule:

<u>Reporting Period</u>	<u>Report Due in MCES office by</u>
January 1 - June 30	July 31
July 1 - December 31	January 31

A complete report consists of a Reporting Period Summary SMR with the operations and water volume summary data for the reporting period, as well as all required attachments listed in Section F of this Permit. All certification questions shall be answered and other pertinent information shall be included, such as significant problems or process changes that have occurred each reporting period.

b. Sampling Results SMR

The Permittee shall submit a complete report by the last day of the month following the month in which the sample was collected. See Attachment A for the sampling frequency required for each listed parameter.

A complete report consists of a Sampling Results SMR and a copy of all laboratory data sheets for all samples reported on the SMR. The Permittee shall also submit all required attachments listed in Section F of this Permit. All certification questions shall be answered and any pertinent information shall be included.

C. Compliance Schedule

The Permittee shall install additional pretreatment equipment and/or conduct necessary operation and maintenance to comply with the Discharge Limitations in accordance with the schedule set forth in:

Not Applicable

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

D. General Permit Conditions

1. All discharges into public sewers by the Permittee shall be in accordance with applicable provisions of the Waste Discharge Rules for the MDS and this Permit.
2. The Permittee shall not knowingly make any false statement, representation or certification in any record, report, plan or other document submitted to MCES.
3. This Permit shall not release the Permittee from any liability, duty or penalty imposed by local, state or federal statutes, regulations, ordinances or license requirements regarding waste disposal.
4. This Permittee shall take all reasonable precautions to minimize all accidental discharges including prohibited slugs, spills, and bypasses. Plans for the prevention and control of accidental discharges shall be submitted to the Industrial Waste & Pollution Prevention Section for approval within a specific period of time when required by MCES. **In the event of any significant accidental discharge, spill, or bypass, the Permittee shall IMMEDIATELY notify the Minnesota State Duty Officer at (651) 649-5451 and report the facility address, and other pertinent information.**

In accordance with Waste Discharge Rule 412, the Permittee shall post a permanent notice on an employee bulletin board or other prominent place advising employees how to notify the Minnesota State Duty Officer in the event of an accidental or prohibited slug discharge.
5. The Permittee shall notify the Industrial Waste & Pollution Prevention Section within 24 hours of becoming aware of any violation of the Discharge Limitations in Section A. of this Permit.
6. The Permittee shall pay applicable Permit fees, Strength Charges, Load Charges, self-monitoring report late fees, and other cost recovery fees assessed by MCES.
7. In accordance with Waste Discharge Rule 211, the Permittee shall not assign or transfer an Industrial Discharge Permit to a new owner, or a new location, without the written approval of MCES.
8. In accordance with Waste Discharge Rule 214, the Permittee shall unconditionally allow MCES personnel to enter the Permittee's premises for the purposes of inspection, monitoring, records review or any other actions, needed to verify information received by MCES or determine compliance with the Waste Discharge Rules and this Permit. The Permittee shall not place conditions upon entry of MCES personnel to the Permittee's premises. In the event that an employee of MCES signs any document agreeing to conditions of entry, including, but not limited to confidentiality of information, this Permit supersedes any such agreement.
9. The Permittee shall retain its waste disposal records, in accordance with Waste Discharge Rule 214, for a period of not less than three years.



**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

D. General Permit Conditions (continued)

10. The analytical results for all wastewater monitoring conducted during each reporting period, at the monitoring points(s) specified in this Permit or at points representing the industrial discharge through the monitoring point(s), including in-house sampling and analysis, shall be submitted with each Sampling Results SMR. All analytical results shall include the operating day discharge volume. Permittees conducting more than one sampling event, in accordance with Permit requirements in Section B, during a reporting period, shall compute an arithmetic average for all parameters subject to EPA Categorical Pretreatment Standards. The average operating day discharge volume shall also be included. All instantaneous field pH results taken during sampling events shall be submitted with the Sampling Results SMR. Unless otherwise noted, only the in-house continuous pH charts corresponding to sampling events are required to be submitted. For all cases where a pH range is required, the minimum and maximum value in the range of measured values shall be listed.
11. If applicable, the Permittee shall install, operate, and maintain sampling and monitoring devices in proper working order at the Permittee's expense.
12. The Permittee shall notify the Industrial Waste & Pollution Prevention Section at least 60 days prior to making changes, such as:
  - moving, adding, or replacing processes or equipment, or
  - modification of the wastewater monitoring point, or
  - installation or modification of wastewater pretreatment equipment, or
  - any other operational changes that would significantly affect the volume or characteristics of the wastewater discharged.

This Permit shall then be subject to modification or reissuance in accordance with Waste Discharge Rules 206-209.

13. The Permittee shall be subject to civil liability as a result of discharges which violate the Waste Discharge Rules, applicable federal pretreatment standards or requirements, or any requirement or condition contained in this Permit. Further, any violation may also result in the Permittee being subject to civil and/or criminal penalties in the amount of \$1,000 per day, 90 days imprisonment, or both.
14. Information and data that Permittees submit to MCES shall be available to the public as required by Waste Discharge Rule 221, the Minnesota Government Data Practices Act, Minnesota Statutes, chapter 13, 40 CFR part 403.14 or any other applicable law. The Permittee may make a written request that certain submitted information remain confidential by submitting the Confidential Business Information Request Form. If MCES determines that this information is eligible for classification as confidential, then the information will not be made available to the public. Information determined to be confidential will remain available only to MCES or any other public agency with the authority to view such information. Information that MCES needs to determine applicable regulations, compliance with the Waste Discharge Rules, or characteristics of the wastewater discharge cannot be deemed confidential.

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

E. Specific Permit Conditions

1. Wastewater Volume Review - The results of the wastewater volume review conducted prior to the reissuance of this Industrial Discharge Permit indicate that the Permittee is not required to pay additional Sewer Availability Charge (SAC) units at this time. Future increases in wastewater volume discharged to the Metropolitan Disposal System will be subject to SAC payment requirements.
2. The Permittee shall make a reasonable effort to conduct self-monitoring projects on days when there is industrial waste discharge through all three monitoring points: SP-01, SP-02 and SP-03. If it is not possible to conduct self-monitoring on days with discharge from all three monitoring points, then samples shall only be collected from the monitoring points with discharge. The SP-04 composite shall then be based on only the monitoring points that carried process discharge.
3. The two self-monitoring projects that the permittee conducts each year shall be conducted at least 30 days apart.

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

F. Required SMR Submittals

Sampling Results SMR

The following items shall be submitted as an attachment to each submitted Sampling Results SMR:

1. The analytical results for all wastewater monitoring conducted during each reporting period, at the monitoring points(s) specified in this Permit or at points representing the industrial discharge through the monitoring point(s), including in-house sampling and analysis, shall be submitted with each Sampling Results SMR.
2. On sampling days, the Permittee shall collect a grab sample at each monitoring point carrying discharge and analyze it for pH according to Standard Method 4500-H+. These readings shall be submitted with the corresponding Sampling Results SMR.
3. The Permittee shall record the pH of the 24-hour composite sample for SP-04, in addition to collecting grab samples for pH analysis at SP-01, SP-02 and SP-03. The SP-04 composite pH result shall be submitted as part of each Sampling Results SMR.

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

Attachment A

Sampling Requirements from Section B.2.

**Sampling Location: SP-01 - Process Wastewater Sump**

<b>Analytical Method (1)</b>	<b>Analyte Description</b>	<b>Minimum Sample Collection Frequency (2)</b>
SM 4500-H+	Instantaneous Field pH	One Sample Semi-Annually

**Sampling Location: SP-02 - Southwest Maintenance Hole**

<b>Analytical Method (1)</b>	<b>Analyte Description</b>	<b>Minimum Sample Collection Frequency (2)</b>
SM 4500-H+	Instantaneous Field pH	One Sample Semi-Annually

**Sampling Location: SP-03 - Southeast Maintenance Hole**

<b>Analytical Method (1)</b>	<b>Analyte Description</b>	<b>Minimum Sample Collection Frequency (2)</b>
SM 4500-H+	Instantaneous Field pH	One Sample Semi-Annually

**Sampling Location: SP-04 - Flow-proportionally combined composite of SP-01, SP-02, and SP-03.**

<b>Analytical Method (1)</b>	<b>Analyte Description</b>	<b>Minimum Sample Collection Frequency (2)</b>
See (3) Below	Composite pH	One Sample Semi-Annually
SM 2540D	Total Suspended Solids	One Sample Semi-Annually
EPA 410.4	Chemical Oxygen Demand	One Sample Semi-Annually

- (1) All samples shall be collected, preserved and analyzed in accordance with the procedures and methods established above and/or in 40 Code of Federal Regulations Part 136 and amendments.
- (2) Sampling and/or analysis is not required during reporting periods when there is no discharge to the Metropolitan Disposal System.
- (3) MCES recognizes that the "Sample Handling and Preservation" does not fully adhere to Standard Method 4500-H+, however, all other requirements of Standard Method 4500-H+ shall be followed to obtain the pH measurement(s).

**METROPOLITAN COUNCIL ENVIRONMENTAL SERVICES (MCES)**

Attachment B

MDS Limitations on Discharges

1. Local Pretreatment Standards - Waste Discharge Rule 401.00  
(Applicable to the total facility discharge)

Parameter	Standard (mg/L)
Cadmium (Cd)	1.0
Chromium - total (Cr)	6.0
Copper (Cu)	4.0
Cyanide - total (CN)	4.0
Lead (Pb)	1.0
Mercury (Hg)	0.002
Nickel (Ni)	6.0
Zinc (Zn)	6.0
pH - maximum (Std Units)	11.0
pH - minimum (Std Units)	5.0

Local pretreatment standards for metals and cyanide are the maximum for any 24 hour period.

pH standards are continuous and apply at all times.