



**Monthly Tank and Container Inspection Form
UMC-Bulk Containers**

Month, Year:

Instructions: This form is specific to the operational area noted above. Complete this inspection form monthly for each regulated tank or container in the operational area at the Facility for proper operation, damage, leaks and suitability for continued service. Regulated tanks that has a capacity of more than 55 gallons, including above-ground and under-ground storage tanks used for any chemical; bulk and waste oil containers; and grease dumpsters. Forward completed checklists monthly to campus EHS staff; EHS staff maintains inspection documentation onsite for 3 years (10 years for USTs) from the date of the inspection.

Date and time of inspection:	Name of inspector:
------------------------------	--------------------

Part A. Tank /Container Visual Check

Review all containers and tanks, piping and associated equipment and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	AST001 (C) Other, Farm Shop, 113, outdoors on east side Oils and Lubricants, Used (425)	AST002 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST003 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST004 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST005 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST006 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST007 (C) Other, Grounds Shop, 106 Oils and Lubricants, Unused (70)	AST008 (C) Other, Grounds Shop, 106 Oils and Lubricants, Unused (70)
1. Labels and signage for tank/container area in place, legible and accurate (USTs must be color-coded).								
2. Exterior of tank or container/s, including paint and coatings, is in good condition, with no evidence of leaking around the tank/container, concrete pad or ground.								
3. Tank openings are properly sealed and vents are clear of obstructions.								
4. Above-ground piping, valves, pumps, tank sensors and associated equipment are in good condition with no evidence of leaking.								
5. Below-ground piping, valves, pumps, tank sensors and associated equipment are in good condition with no evidence of leaking.								
6. Dispenser and pump area, including hose, swivels, nozzle & breakaway (if present) are in good condition and with no evidence of leaking.								
7. Level gauge/sight glass (if present) is readable and in good condition.								
8. Foundations and supports are structurally sound, free from corrosion and other damage, and in good condition.								
9. Grounding straps, wires and sensors are secure, free from corrosion and other damage and in good condition.								
10. Individual containers are closed, labeled and completely in containment area.								
11. Individual containers do not have any noticeable container distortions, buckling, denting or bulging evident.								

Part B. Containment Areas and Release Detection Equipment

Review containment areas associated with containers and tanks and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	AST001 (C) Other, Farm Shop, 113, outdoors on east side Oils and Lubricants, Used (425)	AST002 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST003 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST004 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST005 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST006 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST007 (C) Other, Grounds Shop, 106 Oils and Lubricants, Unused (70)	AST008 (C) Other, Grounds Shop, 106 Oils and Lubricants, Unused (70)
1. Containment area is dry or has a minimal level of standing water.								
2. There is no evidence of release or regulated substance in containment area or interstitial space between tanks (check pop-up sensor).								
3. Drain valves are secured in closed position and have no debris or fire hazard present. All valves in tank system function properly.								
4. Containment structures are in good condition and free from cracks, chipping or other damage, and in good condition.								
5. For tank equipped with leak detection, overflow or gauging equipment installed, system is functioning properly.								
6. For underground tank, tank sump and spill bucket (fill line) does not have evidence of free product, water and debris.								

Part C. Safety Precautions & General Conditions

Review containment areas associated with containers and tanks and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	AST001 (C) Other, Farm Shop, 113, outdoors on east side Oils and Lubricants, Used (425)	AST002 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST003 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST004 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST005 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST006 (C) Other, Farm Shop, 105, Northwest corner of the building Oils and Lubricants,	AST007 (C) Other, Grounds Shop, 106 Oils and Lubricants, Unused (70)	AST008 (C) Other, Grounds Shop, 106 Oils and Lubricants, Unused (70)
1. Safety equipment is in place and operative. Fire extinguishers in place.								
2. Tank system secured to prevent vandalism and unauthorized use.								
3. Spill response supply at each location is adequate to respond to spill at that location.								
4. There are no other conditions that should be addressed for continued safe operation or that may affect the site SPCC plan.								
5. Information on site map & list is complete and accurate.								

Findings/Comments:



Monthly Tank and Container Inspection Form
UMC-Bulk Containers

Month, Year:

Instructions: This form is specific to the operational area noted above. Complete this inspection form monthly for each regulated tank or container in the operational area at the Facility for proper operation, damage, leaks and suitability for continued service. Regulated tanks that has a capacity of more than 55 gallons, including above-ground and under-ground storage tanks used for any chemical; bulk and waste oil containers; and grease dumpsters. Forward completed checklists monthly to campus EHS staff; EHS staff maintains inspection documentation onsite for 3 years (10 years for USTs) from the date of the inspection.

Date and time of inspection:	Name of inspector:
------------------------------	--------------------

Part A. Tank /Container Visual Check

Review all containers and tanks, piping and associated equipment and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	AST009 (C) Other, Grounds Shop, 106 Oils and Lubricants, Used (70)	AST010 (C) Other, Old Farm Shop, East of building Diesel Fuel, Fuel Oil No 2 (3000)	AST011 (C) Other, Old Farm Shop, East of building Gasoline, Unleaded (2000)	DS001 (C) Other, Farm Shop Oils and Lubricants, Used (110)	DS002 (C) Other, Grounds Shop, None Oils and Lubricants, Used (220)	DS004 (C) 809 - OWEN HALL, 180 Oils and Lubricants, Used (55)	GD001 (C) 815 - SAHLSTROM CONFERENCE CENTER, Outside of garage north of the	GD002 (C) 899 - EVERGREEN HALL, North of the building, within solid waste dumpster enclosure
1. Labels and signage for tank/container area in place, legible and accurate (USTs must be color-coded).								
2. Exterior of tank or container/s, including paint and coatings, is in good condition, with no evidence of leaking around the tank/container, concrete pad or ground.								
3. Tank openings are properly sealed and vents are clear of obstructions.								
4. Above-ground piping, valves, pumps, tank sensors and associated equipment are in good condition with no evidence of leaking.								
5. Below-ground piping, valves, pumps, tank sensors and associated equipment are in good condition with no evidence of leaking.								
6. Dispenser and pump area, including hose, swivels, nozzle & breakaway (if present) are in good condition and with no evidence of leaking.								
7. Level gauge/sight glass (if present) is readable and in good condition.								
8. Foundations and supports are structurally sound, free from corrosion and other damage, and in good condition.								
9. Grounding straps, wires and sensors are secure, free from corrosion and other damage and in good condition.								
10. Individual containers are closed, labeled and completely in containment area.								
11. Individual containers do not have any noticeable container distortions, buckling, denting or bulging evident.								

Part B. Containment Areas and Release Detection Equipment

Review containment areas associated with containers and tanks and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	AST009 (C) Other, Grounds Shop, 106 Oils and Lubricants, Used (70)	AST010 (C) Other, Old Farm Shop, East of building Diesel Fuel_Fuel Oil No 2 (3000)	AST011 (C) Other, Old Farm Shop, East of building Gasoline, Unleaded (2000)	DS001 (C) Other, Farm Shop Oils and Lubricants, Used (110)	DS002 (C) Other, Grounds Shop, None Oils and Lubricants, Used (220)	DS004 (C) 809 - OWEN HALL, 180 Oils and Lubricants, Used (55)	GD001 (C) 815 - SAHLSTROM CONFERENCE CENTER, Outside of garage north of the	GD002 (C) 899 - EVERGREEN HALL, North of the building, within solid waste dumpster enclosure
1. Containment area is dry or has a minimal level of standing water.								
2. There is no evidence of release or regulated substance in containment area or interstitial space between tanks (check pop-up sensor).								
3. Drain valves are secured in closed position and have no debris or fire hazard present. All valves in tank system function properly.								
4. Containment structures are in good condition and free from cracks, chipping or other damage, and in good condition.								
5. For tank equipped with leak detection, overflow or gauging equipment installed, system is functioning properly.								
6. For underground tank, tank sump and spill bucket (fill line) does not have evidence of free product, water and debris.								

Part C. Safety Precautions & General Conditions

Review containment areas associated with containers and tanks and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	AST009 (C) Other, Grounds Shop, 106 Oils and Lubricants, Used (70)	AST010 (C) Other, Old Farm Shop, East of building Diesel Fuel_Fuel Oil No 2 (3000)	AST011 (C) Other, Old Farm Shop, East of building Gasoline, Unleaded (2000)	DS001 (C) Other, Farm Shop Oils and Lubricants, Used (110)	DS002 (C) Other, Grounds Shop, None Oils and Lubricants, Used (220)	DS004 (C) 809 - OWEN HALL, 180 Oils and Lubricants, Used (55)	GD001 (C) 815 - SAHLSTROM CONFERENCE CENTER, Outside of garage north of the	GD002 (C) 899 - EVERGREEN HALL, North of the building, within solid waste dumpster enclosure
1. Safety equipment is in place and operative. Fire extinguishers in place.								
2. Tank system secured to prevent vandalism and unauthorized use.								
3. Spill response supply at each location is adequate to respond to spill at that location.								
4. There are no other conditions that should be addressed for continued safe operation or that may affect the site SPCC plan.								
5. Information on site map & list is complete and accurate.								

Findings/Comments:



Monthly Tank and Container Inspection Form
UMC-Bulk Containers

Month, Year:

Instructions: This form is specific to the operational area noted above. Complete this inspection form monthly for each regulated tank or container in the operational area at the Facility for proper operation, damage, leaks and suitability for continued service. Regulated tanks that has a capacity of more than 55 gallons, including above-ground and under-ground storage tanks used for any chemical; bulk and waste oil containers; and grease dumpsters. Forward completed checklists monthly to campus EHS staff; EHS staff maintains inspection documentation onsite for 3 years (10 years for USTs) from the date of the inspection.

Date and time of inspection:	Name of inspector:
------------------------------	--------------------

Part A. Tank /Container Visual Check

Review all containers and tanks, piping and associated equipment and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	GEN001 (C) 813 - KIEHLE BUILDING, West Side Diesel Fuel_ Fuel Oil No 2 (200)	GEN003 (C) 840 - SARGEANT STUDENT CENTER, Outdoors on north side Diesel Fuel_ Fuel Oil	MobGen001 (C) Other, Transportation Garage Diesel Fuel_ Fuel Oil No 2 (80)	MobGen002 (C) Other, Transportation Garage Diesel Fuel_ Fuel Oil No 2 (80)				
1. Labels and signage for tank/container area in place, legible and accurate (USTs must be color-coded).								
2. Exterior of tank or container/s, including paint and coatings, is in good condition, with no evidence of leaking around the tank/container, concrete pad or ground.								
3. Tank openings are properly sealed and vents are clear of obstructions.								
4. Above-ground piping, valves, pumps, tank sensors and associated equipment are in good condition with no evidence of leaking.								
5. Below-ground piping, valves, pumps, tank sensors and associated equipment are in good condition with no evidence of leaking.								
6. Dispenser and pump area, including hose, swivels, nozzle & breakaway (if present) are in good condition and with no evidence of leaking.								
7. Level gauge/sight glass (if present) is readable and in good condition.								
8. Foundations and supports are structurally sound, free from corrosion and other damage, and in good condition.								
9. Grounding straps, wires and sensors are secure, free from corrosion and other damage and in good condition.								
10. Individual containers are closed, labeled and completely in containment area.								
11. Individual containers do not have any noticeable container distortions, buckling, denting or bulging evident.								

Part B. Containment Areas and Release Detection Equipment

Review containment areas associated with containers and tanks and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	GEN001 (C) 813 - KIEHLE BUILDING, West Side Diesel Fuel_ Fuel Oil No 2 (200)	GEN003 (C) 840 - SARGENT STUDENT CENTER, Outdoors on north side Diesel Fuel_ Fuel Oil No	MobGen001 (C) Other, Transportation Garage Diesel Fuel_ Fuel Oil No 2 (80)	MobGen002 (C) Other, Transportation Garage Diesel Fuel_ Fuel Oil No 2 (80)				
1. Containment area is dry or has a minimal level of standing water.								
2. There is no evidence of release or regulated substance in containment area or interstitial space between tanks (check pop-up sensor).								
3. Drain valves are secured in closed position and have no debris or fire hazard present. All valves in tank system function properly.								
4. Containment structures are in good condition and free from cracks, chipping or other damage, and in good condition.								
5. For tank equipped with leak detection, overflow or gauging equipment installed, system is functioning properly.								
6. For underground tank, tank sump and spill bucket (fill line) does not have evidence of free product, water and debris.								

Part C. Safety Precautions & General Conditions

Review containment areas associated with containers and tanks and indicate whether the following criteria are met. Indicate "Yes", "No" or "N/A" for each item. For any answer indicated as "No", indicate specific finding, corrective action(s) required, along with the date, time and person(s) notified of actions required.	GEN001 (C) 813 - KIEHLE BUILDING, West Side Diesel Fuel_ Fuel Oil No 2 (200)	GEN003 (C) 840 - SARGENT STUDENT CENTER, Outdoors on north side Diesel Fuel_ Fuel Oil	MobGen001 (C) Other, Transportation Garage Diesel Fuel_ Fuel Oil No 2 (80)	MobGen002 (C) Other, Transportation Garage Diesel Fuel_ Fuel Oil No 2 (80)				
1. Safety equipment is in place and operative. Fire extinguishers in place.								
2. Tank system secured to prevent vandalism and unauthorized use.								
3. Spill response supply at each location is adequate to respond to spill at that location.								
4. There are no other conditions that should be addressed for continued safe operation or that may affect the site SPCC plan.								
5. Information on site map & list is complete and accurate.								

Findings/Comments: