

Regulatory Reporting of Spills

J. Rantala, EQA/EC, rev. 05/04/2010

A spill is contained only if there is no release to air, water or land. Spills inside buildings that volatilize and then are exhausted to the atmosphere are uncontained spills. Spills that can be conveyed to the ground or water are uncontained spills. Spills into AST containment areas may be uncontained, depending on specific circumstances.



